

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Disinfection Byproduct and Monitoring Violation at Nyack Water System

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results from May 2025 through February 2026 show that our system exceeds the standard, or maximum contaminant level (MCL), for Trihalomethane (TTHM). The standard for TTHM is 80 ug/L. It is determined by averaging all the samples collected at each sampling location for the prior 12 months. The level of TTHM averaged at three of our system's sample locations for May 2025 through February 2026 were 92 ug/L, 83 ug/L, and 81 ug/l respectively. In addition, a monitoring violation for collecting two samples outside of the sampling window.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been an emergency, you would have been notified within 24 hours.

Trihalomethanes are disinfection byproducts formed during treatment of drinking water by chlorine, the most commonly used disinfectant in New York State. Drinking water is disinfected by public water suppliers to kill bacteria and viruses that could cause serious illnesses. For this reason, disinfection of drinking water by chlorination is beneficial to public health. The amount of trihalomethanes in drinking water can change from day to day, depending on the temperature, the amount of organic material in the source water, the amount of chlorine added, and a variety of other factors. All public water systems that use chlorine as a disinfectant contain trihalomethanes to some degree.

The following paragraph summarizes and characterizes the available studies on human populations exposed to trihalomethanes, and provides a general summary of the health effects of trihalomethanes in animals, which occur at exposure levels much higher than exposures that could result through normal use of the water.

Some studies suggest that people who drank water containing trihalomethanes for long periods of time (e.g., 20 to 30 years) have an increased risk of certain health effects. These include an increased risk for cancer and for low birth weights, miscarriages and birth defects. The methods used by these studies could not rule out the role of other factors that could have resulted in the observed increased risks. In addition, other similar studies do not show an increased risk for these health effects. Therefore, the evidence from these studies is not strong enough to conclude that the observed increased risk for health effects is due to trihalomethanes, other disinfection by-products, or some other factor. Studies of laboratory animals show that some trihalomethanes can cause cancer and adverse reproductive and developmental effects after high levels of exposure. The risks for adverse health effects from trihalomethanes in drinking water are small compared to the risks for illness from drinking inadequately disinfected water.

What is being done?

The Village of Nyack Water Department experienced delays in its forecast regarding the installation of a new GridBee TTHM (Total Trihalomethanes) removal system. Delays had occurred while awaiting Orange & Rockland installation of a new utility pole on Dickinson Ave, Nyack, as well as coordination confirmation on installation process and approvals to meet local county and New York State Department of Health compliance standards. Materials and other required provisions have been acquired or completed. THM Removal System installation approval was received May 1st, 2026 with projected installation to begin after July 4th, 2026.

For more information, please contact Thomas Lynch, Superintendent of Nyack Water, at 845-358-3734 or thomaslynch@nyack-ny.gov, or the Rockland County Department of Health at 845-364-2608.

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the Village of Nyack Water Department.

State Water System ID#: 4303666.

Date distributed: 5/14/26